

	Δp [mbar]	2000 rpm			2250 rpm			2500 rpm			2750 rpm			2900 rpm			3250 rpm			3500 rpm			3750 rpm			4000 rpm		
		Q [m³/h]	P [kW]	P _n [kW]	Q [m³/h]	P [kW]	P _n [kW]	Q [m³/h]	P [kW]	P _n [kW]	Q [m³/h]	P [kW]	P _n [kW]	Q [m³/h]	P [kW]	P _n [kW]	Q [m³/h]	P [kW]	P _n [kW]	Q [m³/h]	P [kW]	P _n [kW]	Q [m³/h]	P [kW]	P _n [kW]	Q [m³/h]	P [kW]	P _n [kW]
DRUCKBETRIEB	600	-	-	-	-	-	-	-	-	-	-	-	-	708	23.18	30.00	861	26.86	30.00	967	29.68	37.00	1072	32.69	37.00	-	-	-
	550	-	-	-	-	-	-	-	-	-	669	20.27	30.00	735	21.69	30.00	885	25.21	30.00	991	27.93	30.00	1094	30.83	37.00	1196	33.92	37.00
	500	-	-	-	-	-	-	-	-	-	697	18.84	30.00	762	20.19	22.00	910	23.56	30.00	1014	26.18	30.00	1117	28.97	37.00	1218	31.96	37.00
	450	-	-	-	-	-	-	616	15.40	22.00	725	17.42	22.00	789	18.70	22.00	936	21.92	30.00	1038	24.42	30.00	1140	27.11	30.00	1240	29.99	37.00
	400	-	-	-	537	12.31	22.00	646	14.08	22.00	753	15.99	22.00	816	17.21	22.00	961	20.27	22.00	1063	22.67	30.00	1163	25.25	30.00	1262	28.03	30.00
	350	-	-	-	569	11.11	22.00	677	12.76	22.00	782	14.56	22.00	844	15.71	22.00	987	18.63	22.00	1087	20.92	22.00	1186	23.40	30.00	1284	26.07	30.00
	300	494	8.50	22.00	602	9.91	22.00	708	11.45	22.00	811	13.13	22.00	872	14.22	22.00	1013	16.98	22.00	1112	19.17	22.00	1210	21.54	30.00	1307	24.10	30.00
	250	530	7.41	22.00	636	8.70	22.00	739	10.13	22.00	840	11.70	22.00	900	12.72	22.00	1039	15.34	22.00	1136	17.41	22.00	1233	19.68	22.00	1329	22.14	30.00
	200	567	6.32	22.00	670	7.50	22.00	771	8.81	22.00	870	10.28	22.00	929	11.23	22.00	1065	13.69	22.00	1161	15.66	22.00	1257	17.82	22.00	1352	20.18	22.00
	150	604	5.23	22.00	704	6.29	22.00	803	7.50	22.00	900	8.85	22.00	958	9.74	22.00	1092	12.05	22.00	1186	13.91	22.00	1281	15.96	22.00	1374	18.21	22.00
	100	643	4.14	22.00	740	5.09	22.00	836	6.18	22.00	930	7.42	22.00	987	8.24	22.00	1118	10.40	22.00	1212	12.16	22.00	1305	14.10	22.00	1397	16.25	22.00
	50	682	3.05	22.00	775	3.89	22.00	869	4.86	22.00	961	5.99	22.00	1017	6.75	22.00	1145	8.75	22.00	1237	10.40	22.00	1329	12.25	22.00	1420	14.29	22.00
	0	722	1.96	22.00	812	2.68	22.00	902	3.55	22.00	992	4.57	22.00	1046	5.26	22.00	1173	7.11	22.00	1263	8.65	22.00	1353	10.39	22.00	1443	12.32	22.00
VAKUUMBETRIEB	50	693	3.35	18.50	785	4.14	18.50	877	5.03	18.50	969	6.02	18.50	1024	6.66	18.50	1152	8.28	18.50	1244	9.56	18.50	1335	10.94	18.50	1426	12.41	18.50
	100	652	4.30	18.50	747	5.20	18.50	841	6.20	18.50	935	7.28	18.50	991	7.98	18.50	1121	9.75	18.50	1214	11.13	18.50	1306	12.61	18.50	1398	14.19	18.50
	150	602	5.25	18.50	702	6.26	18.50	799	7.36	18.50	896	8.55	18.50	953	9.31	18.50	1086	11.22	18.50	1180	12.70	18.50	1273	14.28	18.50	1367	15.96	18.50
	200	543	6.20	18.50	649	7.31	18.50	751	8.52	18.50	851	9.81	18.50	910	10.64	18.50	1046	12.69	18.50	1142	14.27	18.50	1237	15.95	18.50	1332	17.73	22.00
	250	-	-	-	588	8.37	18.50	696	9.68	18.50	800	11.08	18.50	862	11.96	18.50	1002	14.16	18.50	1101	15.84	18.50	1198	17.62	22.00	1295	19.50	22.00
	300	-	-	-	-	-	-	635	10.84	18.50	744	12.34	18.50	808	13.29	18.50	954	15.63	18.50	1055	17.41	18.50	1155	19.29	22.00	1254	21.27	30.00
	350	-	-	-	-	-	-	-	-	-	683	13.61	18.50	750	14.61	18.50	901	17.10	18.50	1006	18.98	22.00	1109	20.96	30.00	1210	23.04	30.00
	400	-	-	-	-	-	-	-	-	-	-	-	-	687	15.94	18.50	845	18.57	22.00	953	20.55	22.00	1059	22.64	30.00	1163	24.81	30.00

Toleranz auf die angegebenen Werte $\pm 10\%$.

Änderungen der Daten ohne vorherige Ankündigung vorbehalten.

Kennlinien bezogen auf Luft bei einer Temperatur von 20 °C und atmosphärischem Druck von 1013 mbar (abs).